



Supplemental Specification

Corporate • P.O. Box 397 • Fortson • Georgia • 31808 • 800-755-0825 • FAX 706-569-6704
Technical • 800-760-2861 • FAX 734-433-0930

Section 08000 Door & Window Trades

In addition to project requirements, please verify the following minimum information is included in the project (these are not complete specifications).

Part 1 GENERAL

1.1 References

- A. NWWDA – Window and Door Manufacturers Association
- B. AAMA – American Architectural Manufacturers Association
- A. Applicable Building Codes; BOCA, ICBO, ICC, SBCCI.

PART 2 PRODUCTS

2.01 GENERAL

- A. Door and window installation shall conform with manufacturer guidelines and in coordination with good installation practices.
- B. The design pressure rating of exterior windows and doors in buildings shall be determined in accordance with applicable building codes.

2.02 MATERIALS

- 1. **Windows/Doors:** Aluminum, vinyl and wood exterior windows and glass doors shall be labeled as conforming to AAMA/NWWDA/101/I.S.2. The label shall state the name of the manufacturer, the approved labeling agency and the product designation as specified in AAMA/NWWDA/101/I.S.2. Exterior window and door assemblies not conforming to the above test standard shall be tested in accordance with ASTM E-330 to the satisfaction of the local jurisdictional building authority. Pella Proline Series double hung windows with a maximum size of 3'-1" wide by 5'-5" high and Stanley Basic Utility Door with a maximum size of 3'-0" wide by 6'-8" high for BOCA Jurisdictions.

PART 3 EXECUTION

3.01 INSTALLATION

- A. Install units according to manufacturer's published instructions.
- B. Perform necessary maintenance on the window units according to manufacturers' instructions. Disassemble the window and check head, jamb and sill conditions. Add sealant where necessary. Seal any visible holes in the window frame including factory head/jamb plastic insert and shim adjuster (on Pella windows), seal between the aluminum and wood jambs, and examine/seal the framing for defects such as check cracking.

Disclaimer

This Specification is published for general informational purposes only and is not intended to imply that these are the only materials, procedures, or methods, which are available or suitable. Materials, procedures, or methods may vary according to the particular circumstances, local building code requirements, design conditions, or statutory and regulatory requirements. While the information in this specification is believed to be accurate and reliable, it is presented without guarantee or responsibility on the part of Master Wall Inc.