



## Field Observation Form - Specialties

Project Name:  
 Address:  
 Address:  
 City, State:

Date:  
 Time:  
 Weather:  
 Applicator:  
 Author:

System:	System/Product	Comments
---------	----------------	----------

Design Check	Comments
Expansion Joints at Floor Line?	
Exp. Jts. at substrate changes?	
Proper slope on shapes (1:2)	
Other	

Substrates	Comments (fastening, clean, flat, dry, etc.)
Substrate 1	
Substrate 2	
Substrate 3	
Wood sheathing properly gapped?	
Fastening Pattern?	

Water Barriers	Comments (shingle fashion, lapping, attachment, repairs)
Water Barrier	
Installed Shingle Fashion?	
Lapped 2" hor/6" vert or per mfr?	
Hammer tacker staples 3/8" or less?	
or Roofing nails/similar at framing	
Mesh at joints (fluid)	
Tears repaired?	
Other	



## Field Observation Form - Specialties (page 2)

<b>Penetrations &amp; Flashing</b>	<b>Comments</b> (types, details, etc)
------------------------------------	---------------------------------------

Window Splining/Peel and Stick:  
 Window Head Flashing:  
 Roof Kick Out Flashing:  
 Small Penetration Sealant:  
 Other Flashing:  
 Other Comments:

<b>Accessories</b>	Cement Board & Soffit	<b>Comments</b>
--------------------	-----------------------	-----------------

**Accessory Type**

Design: Control joints located on documents:  
 Maximum area 160sf:  
 Length/width 2.5:1 or less  
 CJ's at dissimilar substrates  
 Expansion Joints where needed:

<b>Base Coat and Application</b>	<b>Comments</b>
<b>Base Coats</b>	

Correct Mixing Observed?  
 Mesh fully embedded in BC?  
 Approved Thickness?  
 Correct Temperature Range?  
 Cure Temperature Maintained?  
 Other:



## Field Observation Form - Specialties (page 3)

---

### Mesh Application & Terminations

### Comments

Mesh 1

Mesh 2

Lapped/Butted Correctly?  
Fully Embedded in Base Coat?  
No Mesh Color Visible?  
Insulation Encapsulated?

**EIFS Terminations**

Other:

---

### Finish Application

### Comments

Finish 1

Finish 2

Dry temperature maintained?  
Other:

---

### Sealants and Finish Installation

### Comments

Sealant Type

Manufacturer:  
Joints installed as directed by A/E?  
Sealant primer installed?  
Correct backer rod/bond breaker?  
Final seal comments:



## Field Observation Form - EIFS (page 4)

---

General/Closing Comments

Photos



## Field Observation Form - Stucco (page 5)

---

General/Closing Comments

Photos