



## Supplemental Specification

Corporate • P.O. Box 397 • Fortson • Georgia • 31808 • 800-755-0825 • FAX 706-569-6704  
Technical • 800-760-2861 • FAX 734-433-0930

---

# Section 073000 Roofing Trades

In addition to project requirements, please verify the following minimum information is included in the project (these are not complete specifications).

## Part 1 GENERAL

### 1.1 References

- A. *NRCA Roofing & Waterproofing Manual*, current edition – National Roofing Contractors Association
- B. Applicable Building Codes; BOCA, ICBO, ICC, SBCCI.

## PART 2 PRODUCTS

### 2.01 GENERAL

- A. Roofing work shall comply with NRCA and building code guidelines and in coordination with good installation practices.

### 2.02 MATERIALS

- A. Roofing
  1. **Roofing Materials:** as recognized by local building codes.
  2. **Secondary Protective Water Barrier:** As required by code and manufacturer, asphalt felt conforming to ASTM D-226.

## PART 3 EXECUTION

### 3.01 INSTALLATION

- A. Install roofing in accordance with manufacturer guidelines and code requirements. As a minimum, steep roofing secondary water barrier should extend vertical walls a minimum of 4 inches (102 mm).
- B. Kicks out flashings are required as referenced in Section 07620.

## Disclaimer

This Specification is published for general informational purposes only and is not intended to imply that these are the only materials, procedures, or methods, which are available or suitable. Materials, procedures, or methods may vary according to the particular circumstances, local building code requirements, design conditions, or statutory and regulatory requirements. While the information in this specification is believed to be accurate and reliable, it is presented without guarantee or responsibility on the part of Master Wall Inc.